



These plans are conditionally approved as submitted or noted on the drawings and are subject to field inspection. Approved plans must be kept on site and are needed for all inspections. No changes or modifications to these plans. Changes require a revision permit with the revised plans. Separate Permits are required for trades such as Electrical or Plumbing.

11150 FAIRFAX BLVD.  
 ANNAPOLIS, MD 21406  
 (410) 293-2000  
 ARCHITECTURE • PLANNING  
 CONSULTING • INTERIORS  
 MARKET ANALYSIS

Electrical Review - Alina Mahmood - 10-24-2017  
 Plumbing Review - Wayne Ferguson - 10-24-2017  
 Elevator Review - Luchi Lu - 10-24-2017  
 DDOT Review - Tiffany Tenbrock - 10-24-2017  
 Mechanical Review - Wayne Ferguson - 10-24-2017  
 DOE SE-SW Review - Nykia Biles - 10-24-2017  
 Energy Review - Robert Campbell - 10-24-2017  
 Fire Review - Luchi Lu - 10-24-2017  
 Structural Review - Abdul Mujib - 10-24-2017  
 DC Water Review - Vahid Bilal - 10-24-2017



NOTE:  
 SEE STRUCTURAL PLANS  
 FOR FOUNDATION PLAN.

**CELLAR PLAN**

SCALE: 1/4" = 1'-0"  
 NOTE:  
 1) REFERENCE TYPICAL WALL SECTION FOR ADDITIONAL INFORMATION.  
 2) PROVIDE 4" DIA. PERIMETER DRAIN TILE AROUND THE EXTERIOR FOOTING AND A 4" DIA. DIAGONAL DRAIN TILE FROM THE SUMP CROCK TO THE OPPOSITE FOUNDATION WALL. SLEEVE FOOTING AS REQUIRED.

SHEET TITLE:  
**CELLAR PLAN**  
**4517 HOBAN RD. NW WASHINGTON, DC 20007**  
**FOXHALL BUILDERS LLC - A & T LOT #875 SQUARE 1346**  
 This drawings is an instrument of service and shall remain the property of Pinnacle Design & Consulting, Inc., it shall not be modified or reproduced in any manner without written permission of Pinnacle Design & Consulting, Inc.

DRAWN BY: MAQ	DATE: 06/07/2017
REV No.	DATE

SHEET No.  
**40201**